



CB TEST CERTIFICATE

Ref. Certificate No.

NL-13384

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by: KEMA Quality B.V.

Product: Air circuit-breaker

Applicant: LS Industrial Systems Co. Ltd. 84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul, Korea Korea, Republic of

Manufacturer: LS Industrial Systems Co. Ltd. 84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul, Korea Korea, Republic of

Factory: LS Industrial Systems Co., Ltd. CheongJu Plant 1, Songjeong-dong, Heungdeok-gu Cheongju-si, Chungcheongbuk-do, Korea Korea, Republic of

Rating and principal characteristics: 3/4 pole ACB (Electronic trip unit)
In = 630 A, 800 A, 1000 A, 1250A, 1600 A, 2000 A
Ue = 220, 230, 380, 415, 440, 460, 480, 500, 550, 600, 690 V
Ui = 1000 Vac
Uimp = 12 kV
Icu = AN type: 50 kA-690 V, 65 kA-500 V, AS type: 65 kA-690 V, 70 kA-500 V, AH type: 65 kA-690 V, 85 kA-500 V
Ics = 100%Icu
Icw = AN type: 50kA/1s, AS type & AH type: 65kA/1s
Rated frequency = 50/60 Hz
Cat B

Trade mark (if any): LS

Model/Type reference: 2000 AF: AN-06/08/10/13/16/20D3-; AN-06/08/10/13/16/20D4-; AS-06/08/10/13/16/20D3-; AS-06/08/10/13/16/20D4-; AH-06/08/10/13/16/20D3-; AH-06/08/10/13/16/20D4-

Additional information: -

Sample of product tested to be in conformity with IEC: 60947-2(ed.4)

Test Report Ref. No: 2106131.50

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2007-10-29