



CB TEST CERTIFICATE

Ref. Certificate No.

NL-13387

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

Issued by:	KEMA Quality B.V.		
Product:	Air circuit-breaker		
Applicant:	LS Industrial Systems Co. Ltd.	84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul, Korea	Korea, Republic of
Manufacturer:	LS Industrial Systems Co. Ltd.	84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul, Korea	Korea, Republic of
Factory:	LS Industrial Systems Co., Ltd. CheongJu Plant	1, Songjeong-dong, Heungdeok-gu Cheongju-si, Chungcheongbuk-do, Korea	Korea, Republic of
Rating and principal characteristics:	<p>3/4 pole ACB (Electronic trip unit) $I_n = 4000\text{ A}, 5000\text{ A}, 6300\text{ A}$ $U_e = 220, 230, 380, 415, 440, 460, 480, 500, 550, 600, 690\text{ V}$ $U_i = 1000\text{ Vac}$ $U_{imp} = 12\text{ kV}$ $I_{cu} = \text{AS type: } 120\text{ kA-500 V}, 100\text{ kA-690 V}, \text{AH type: } 150\text{ kA-500 V}, 100\text{ kA-690 V}$ $I_{cs} = 100\%I_{cu}$ $I_{cw} = 100\text{ kA}, 1\text{ s}$ Rated frequency = 50/60 Hz Cat B</p>		
Trade mark (if any):	LS		
Model/Type reference:	6300 AF: AS-40/50/63G3-, AS-40/50/63G4-, AH-40/50/63G3-, AH-40/50/63G4-		
Additional information:	-		
Sample of product tested to be in conformity with IEC:	60947-2(ed.4)		
Test Report Ref. No:	2106131.53		

This CB Test Certificate is issued by the National Certification Body:

KEMA Quality B.V.
 Utrechtseweg 310
 P.O. Box 5185
 6802 ED Arnhem
 The Netherlands



Signed by: H.L. Schendstok

Date of issue: 2007-10-29