



# 中国国家强制性产品认证证书

证书编号: 2004010303130935

## 申请人名称及地址

LS产电  
汉城 中区 南大门路5街 84-11

商标: LS

## 制造商名称及地址

LS产电  
汉城 中区 南大门路5街 84-11

## 生产企业名称及地址

LS产电 清州工厂  
韩国清州市兴德区松正洞1号 361-720

## 产品名称和系列、规格、型号

辅助触点

AU- □ AC-15: Ue/Ie: 110V/6A, 220V/3A, 440V/1.5A, 550V/1.2A DC-13: Ue/Ie:  
24V/3A, 48V/1.5A, 110V/1.1A, 220V/0.55A AC-12: Ue/Ie:  
110V/10A, 220V/8A, 550V/5A DC-13: Ue/Ie: 24V/5A, 48V/3A, 110V/2.5A, 220V/1A  
I<sub>th</sub>=16A

## 产品标准和技术要求

GB14048.5-2001

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2005年6月27日

本证书的有效性依据发证机构的定期监督获得保持!

(本证书为变更证书, 证书首次颁发日期: 2004年9月23日)



主任:

李怀林



中国·北京·朝阳门外大街甲10号 100020 网址: www.cqc.com.cn

A 0204893



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2004010303130935

## NAME AND ADDRESS OF THE APPLICANT

LS Industrial Systems Co., Ltd.  
84-11, Nandaemunno5(o)-ga, Jung-gu, Seoul, Korea

TRADE MARK: LS

## NAME AND ADDRESS OF THE MANUFACTURER

LS Industrial Systems Co., Ltd.  
84-11, Nandaemunno5(o)-ga, Jung-gu, Seoul, Korea

## NAME AND ADDRESS OF THE FACTORY

LS Industrial Systems Co., Ltd. CheongJu Plant  
1. Songjeong-dong, Heungdeok-gu, Cheongju-si, Chungchengbuk-do, Korea

## NAME, MODEL AND SPECIFICATION

Contactor relay

AU- □ AC-15:Ue/Ie: 110V/6A, 220V/3A, 440V/1.5A, 550V/1.2A DC-13:Ue/Ie:  
24V/3A, 48V/1.5A, 110V/1.1A, 220V/0.55A AC-12:Ue/Ie:  
110V/10A, 220V/8A, 550V/5A DC-13:Ue/Ie:24V/5A, 48V/3A, 110V/2.5A, 220V/1A  
Ith=16A

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.5-2001

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR  
THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Jun. 27, 2005

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE  
CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: Sep. 23, 2004)



President:

李怀林

Li Huailin



A10 Chaoyangmenwaidajie Beijing 100020 P.R.China <http://www.cqc.com.cn>

A 0204893