



# 中国国家强制性产品认证证书

证书编号: 2003010304037415

## 申请人名称及地址

LS产电  
汉城 中区 南大门路5街 84-11

商标: LS

## 制造商名称及地址

LS产电  
汉城 中区 南大门路5街 84-11

## 生产企业名称及地址

LS产电 清州工厂  
韩国清州市兴德区松正洞1号

## 产品名称和系列、规格、型号

接触器

型号: GMC-50, GMC-65, GMC-75, GMC-85, GMC-50/4, GMC-65/4, GMC-75/4, GMC-85/4, GMD-50, GMD-65, GMD-75, GMD-85, GMD-50/4, GMD-65/4, GMD-75/4, GMD-85/4,  
Ue=AC380V, 440V, Us=AC24, 48, 100, 110, 220, 240, 380, 400, 415, 440, 500, 550V,  
DC12, 20, 24, 48, 60, 80, 100, 110, 125, 200, 220, 250V, Ith=80A (GMC-50, GMD-50, GMC-50/4, GMD-50/4), 100A (GMC-65, GMD-65, GMC-65/4, GMD-65/4), 110A (GMC-75, GMD-75, GMC-75/4, GMD-75/4), 135A (GMC-85, GMD-85, GMC-85/4, GMD-85/4), Ie= 50A/AC-3 (GMC-50, GMD-50, GMC-50/4, GMD-50/4), 32A/AC-4 (GMC-50, GMD-50, GMC-50/4, GMD-50/4), 65A/AC-3 (GMC-65, GMD-65, GMC-65/4, GMD-65/4), 47A/AC-4 (GMC-65, GMD-65, GMC-65/4, GMD-65/4), 75A/AC-3 (GMC-75, GMD-75, GMC-75/4, GMD-75/4), 52A/AC-4 (GMC-75, GMD-75, GMC-75/4, GMD-75/4), 85A/AC-3 (GMC-85, GMD-85, GMC-85/4, GMD-85/4), 62A/AC-4 (GMC-85, GMD-85, GMC-85/4, GMD-85/4), 3Pole, 4Pole

## 产品标准和技术要求

GB14048.4-1993

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2005年6月27日

本证书的有效性依据发证机构的定期监督获得保持

(本证书为变更证书, 证书下次换证日期: 2007年4月10日)

主任:

李怀林



中国·北京·朝阳门外大街甲10号 100020 网址: www.cqc.com.cn

A 0204875



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010304037415

## NAME AND ADDRESS OF THE APPLICANT

LS Industrial Systems Co., Ltd.  
84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul, Korea

TRADE MARK: LS

## NAME AND ADDRESS OF THE MANUFACTURER

LS Industrial Systems Co., Ltd.  
84-11, Namdaemunno5(o)-ga, Jung-gu, Seoul, Korea

## NAME AND ADDRESS OF THE FACTORY

LS Industrial Systems Co., Ltd. CheongJu Plant  
1. Songjeong-dong, Heungdeok-gu, Cheongju-si, Chungcheongbuk-do, Korea

## NAME, MODEL AND SPECIFICATION

Magnetic Contactor

型号: GMC-50, GMC-65, GMC-75, GMC-85, GMC-50/4, GMC-65/4, GMC-75/4, GMC-85/4, GMD-50, GMD-65, GMD-75, GMD-85, GMD-50/4, GMD-65/4, GMD-75/4, GMD-85/4,  
Ue=AC380V, 440V, Us=AC24, 48, 100, 110, 220, 240, 380, 400, 415, 440, 500, 550V,  
DC12, 20, 24, 48, 60, 80, 100, 110, 125, 200, 220, 250V. Ith=80A(GMC-50, GMD-50, GMC-50/4, GMD-50/4), 100A(GMC-65, GMD-65, GMC-65/4, GMD-65/4), 110A(GMC-75, GMD-75, GMC-75/4, GMD-75/4), 135A(GMC-85, GMD-85, GMC-85/4, GMD-85/4), Ie= 50A/AC-3(GMC-50, GMD-50, GMC-50/4, GMD-50/4), 32A/AC-4(GMC-50, GMD-50, GMC-50/4, GMD-50/4), 65A/AC-3(GMC-65, GMD-65, GMC-65/4, GMD-65/4), 47A/AC-4(GMC-65, GMD-65, GMC-65/4, GMD-65/4), 75A/AC-3(GMC-75, GMD-75, GMC-75/4, GMD-75/4), 52A/AC-4(GMC-75, GMD-75, GMC-75/4, GMD-75/4), 85A/AC-3(GMC-85, GMD-85, GMC-85/4, GMD-85/4), 62A/AC-4(GMC-85, GMD-85, GMC-85/4, GMD-85/4), 3Pole, 4Pole

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-1993

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Jun. 27, 2005



THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: 2005.6.27)  
President:

李怀林

Li Huailin



A10 Chaoyangmenwaidajie Beijing 100020 P.R.China <http://www.cqc.com.cn>

A 0204875