



IEC SYSTEM FOR CONFORMITY
TESTING TO STANDARDS FOR
SAFETY OF ELECTRICAL
EQUIPMENT (IECEE) CB SCHEME

Ref. Certificate No.

NL-7104/1

CB TEST CERTIFICATE

Issued by: KEMA Quality B.V.

Registration date: 2005-05-26

Product: Circuit-breakers for overcurrent

Applicant: LS Industrial Systems Co., Ltd. Cheong Ju Plant, #1, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720 Korea, Republic Of

Manufacturer: LS Industrial Systems Co., Ltd. Cheong Ju Plant, #1, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720 Korea, Republic Of

Factory: LS Industrial Systems Co., Ltd. Cheong Ju Plant, #1, Song Jung Dong, Hung Duk Ku, Cheong Ju, 361-720 Korea, Republic Of

Rating and principal characteristics: In 15, 20, 30 A; Un 110/220 Vac, characteristic D ; 2 protected poles, Ics 1500 A

Trade mark (if any): LS

Model/Type reference: BS32a

Additional information: This CB is reissued due to name changes at the company.

Sample of product tested to be in conformity with IEC: 60898(ed.2)

Test Report Ref. No: 2028086.50 dated: 1-10-2003 (see report)

This CB Test Certificate is issued by the National Certification Body

KEMA Quality B.V.
Utrechtseweg 310
P.O. Box 5185
6802 ED Arnhem
The Netherlands

KEMA

Signed by: H.L. Schendstok

Date of issue: 2005-05-26