

CERTIFICATE OF COMPLIANCE

Certificate Number E214031
Report Reference E214031 – 20041029
Issue Date 2020-APRIL-17

Issued to: LS ELECTRIC Co Ltd
95 Baekbong-ro Heungdeok-gu Cheongju-si
Chungcheongbuk-do 28439 KOREA

This certificate confirms that representative samples of MOTOR CONTROLLERS, MANUAL
See next page for Models

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 508, Industrial Control Equipment
CAN/CSA C22.2 No. 14-13, Industrial Control Equipment

Additional Information: See the UL Online Certifications Directory at <https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number E214031
Report Reference E214031 – 20041029
Issue Date 2020-APRIL-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

PRODUCT COVERED:

USL, CNL - Industrial Control Equipment, Open Type Manual Motor Controllers.
MMS Series. Models MMS-32 followed by H or HI or S, maybe followed by -0.16, -0.25, -0.40, -0.63, -1.0, -1.6, -2.5, -4.0, -6.0, -8.0, -10, -13, -17, -22, -26, -32 or -40. Models MMS-63 followed by H or HI or S, maybe followed by -10, -13, -17, -22, -26, -32, -40, -50, -63 or -65. Models MMS-100 followed by H or HI or S, maybe followed by -17, -22, -26, -32, -40, -50, -63, -75, -90 or -100.

MMS Front Mounted Auxiliary Contact Block Accessory Model FX.

MMS Side Mounted Auxiliary Contact Block Accessory Model LX.

MMS Shunt Release Accessory RS Series.

MMS Undervoltage Release Accessory RU Series.

MMS Undervoltage Release with Switch Accessory RUX Series.

MMS Alarm Switch Accessory Model LA.

MMS Alarm Switch for Magnetic Trip Accessory Model LAM.

MMS Phase-Bus Devices, Type PB-322, PBL-322, PB-323, PBL-323, PB-324, PB-325, PB-632 and PB-633.

Direct Adaptor devices, Type DA, followed by -16, -32, 63 or 95.

MEH Handles for MMS Series, Models MEH followed by -32, -63 or -100, maybe followed by R, followed by -115 or -315.

MMS Line Terminal Block, Type LTB-32.

MMS Terminal Block, Type TB-32.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

