

# CERTIFICATE OF COMPLIANCE

**Certificate Number** E336213  
**Report Reference** E336213-20130520  
**Issue Date** 2020-APRIL-20

**Issued to:** LS ELECTRIC Co Ltd  
95 Baekbong-ro Heungdeok-gu  
Cheongju-si Chungcheongbuk-do 28439 KOREA

**This certificate confirms that  
representative samples of**

COMPONENT - CIRCUIT BREAKERS, ADJUSTABLE  
INSTANTANEOUS TRIP TYPE

USR, CNR - Component - Instantaneous trip circuit breaker,  
Types UTS800, rated 800A, 600Vac, three poles, with suffix  
MCP.

Have been investigated by UL in accordance with the  
component requirements in the Standard(s) indicated on  
this Certificate. UL Recognized components are incomplete  
in certain constructional features or restricted in  
performance capabilities and are intended for installation in  
complete equipment submitted for investigation to UL LLC.

**Standard(s) for Safety:**

UL 489 - Molded-Case Circuit Breakers, Molded-Case  
Switches and Circuit-Breaker Enclosures  
CSA-C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-  
Case Switches, and Circuit-Breaker Enclosures

**Additional Information:**

See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program  
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

