

CERTIFICATE OF COMPLIANCE

Certificate Number E336213
Report Reference E336213-20130516
Issue Date 2020-APRIL-20

Issued to: LS ELECTRIC Co Ltd
95 Baekbong-ro Heungdeok-gu
Cheongju-si Chungcheongbuk-do 28439 KOREA

**This certificate confirms that
representative samples of**

COMPONENT - CIRCUIT BREAKERS, ADJUSTABLE
INSTANTANEOUS TRIP TYPE

USR, CNR - Component - Instantaneous trip circuit breaker,
Types UTS150, rated 1.6 through 150 A, 600Y/347V ac or
600 V, three poles, with suffix MCP.

Have been investigated by UL in accordance with the
component requirements in the Standard(s) indicated on
this Certificate. UL Recognized components are incomplete
in certain constructional features or restricted in
performance capabilities and are intended for installation in
complete equipment submitted for investigation to UL LLC.

Standard(s) for Safety:

UL 489 - Molded-Case Circuit Breakers, Molded-Case
Switches and Circuit-Breaker Enclosures
CSA-C22.2 No. 5 - Molded-Case Circuit Breakers, Molded-
Case Switches, and Circuit-Breaker Enclosures

Additional Information:

See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Recognized Component Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Recognized Component Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Recognized Component Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

