CERTIFICATE OF COMPLIANCE

Certificate Number E231289

Report Reference E231289-20130516

Issue Date 2020-APRIL-17

Issued to: LS ELECTRIC Co Ltd

95 Baekbong-ro Heungdeok-gu

Cheongju-si Chungcheongbuk-do 28439 KOREA

This certificate confirms that representative samples of

CIRCUIT BREAKERS, MOLDED CASE AND CIRCUIT-

BREAKER ENCLOSURES
SEE ADDENDUM PAGE

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 489 and CSA C22.2 No. 5-16 Molded-Case Circuit

Breakers. Molded-Case Switches and Circuit-Breaker

Enclosures

Additional Information: See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutui/locations/



CERTIFICATE OF COMPLIANCE

Certificate Number

E231289

Report Reference

E231289-20130516

Issue Date

2020-APRIL-17

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Molded Case Circuit Breakers - Types UTS1200N, UTS1200P, UTS1200H and UTS1200L, rated 800 through 1200 A, 600 V ac, three poles.



UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

