File E108780 Vol. 1

Sec. 4

Page 6

Issued: 1999-12-07

and Report

Revised: 2005-10-16

CONSTRUCTION DETAILS:

Marking - Device is marked on adhesive-backed label, designated: Listee's name, file number, or trademarks, Type number and electrical ratings.

"60/75°C, Cu wire only", or equivalent.

"Terminal Torque __ in.-lbs (see Ratings)", or equivalent. Torque marking may be provided loose with the equipment.

"Suitable For Use On A Circuit Capable Delivering Not More Than rms Symmetrical Amperes, Volts Maximum. When Protected by Class Fuses.", or equivalent.

The following Trademarks may be used:









Alternate Trademark



File E206826 Project 99SC48292

December 08, 1999

REPORT

ON

AUXILIARY DEVICES

LG Industrial Systems Co. Ltd. Chung Cheong Bug-Do, Korea

Copyright © 1999 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above named company to reproduce this Report provided it is reproduced in its entirety.

File E206826 Vol. 1 Sec. 1 Page 1 Issued: 12-08-99 and Report

DESCRIPTION

PRODUCT COVERED:

USL and CNL - Auxiliary Contactors, Series GMR, followed by -4, -6, or -8, may be followed by D.

Accessories - Auxiliary Contact Block, AU-2 and AU-4.

GENERAL:

These devices are open type auxiliary contact assemblies intended for rail or screw down type mounting.

The AU-2 and AU-4 are intended for mounting atop the auxiliary contactors, GMR series. They connect directly to the plunger of the contactor, opening and/or closing the auxiliary contacts when the plunger is pulled in by the coil.

RATINGS:

A600, P600

NOMENCLATURE:

$$\frac{\text{GMR}}{\text{I}} \quad - \quad \frac{4}{\text{II}} \quad \frac{\text{D}}{\text{III}}$$

- I. Series Designation
- II. Number of Contacts 4: 4 Contacts
 6: 6 Contacts, used w/AU-2
 8: 8 Contacts, used w/AU-4