



中国国家强制性产品认证证书

证书编号: 2003010309037458

申请人名称及地址

LS产电
汉城 中区 南大门路5街 84-11

商标: LS

制造商名称及地址

LS产电
汉城 中区 南大门路5街 84-11

生产企业名称及地址

LS产电 清州工厂
韩国清州市兴德区松正洞1号

产品名称和系列、规格、型号

热过载继电器

型号: GTH-100/3, GTK-100, Ue=AC380V, 440V, Ie= 34~50A, 39~57A, 43~65A, 54~80A, 65~100A, 85~125A, 脱扣级别(Trip class)= 10A, 3Pole

产品标准和技术要求

GB14048.4-1993

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2005年6月27日

本证书的有效性依据发证机构的定期监督获得保持。

(本证书为变更证书, 证书首次颁发日期: 2003年4月11日)



主任:

李怀林



中国·北京·朝阳门外大街甲10号 100020 网址: www.cqc.com.cn

A 0204879



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010309037458

NAME AND ADDRESS OF THE APPLICANT

LS Industrial Systems Co., Ltd.
84-11, Nandaemunno5 (o)-ga, Jung-gu, Seoul, Korea

TRADE MARK: LS

NAME AND ADDRESS OF THE MANUFACTURER

LS Industrial Systems Co., Ltd.
84-11, Nandaemunno5 (o)-ga, Jung-gu, Seoul, Korea

NAME AND ADDRESS OF THE FACTORY

LS Industrial Systems Co., Ltd. CheongJu Plant
1. Songjeong-dong, Heungdeok-gu, Cheongju-si, Chungchengkuk-do, Korea

NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

型号:GTH-100/3, GTK-100, Ue=AC380V, 440V, Ie= 34~50A, 39~57A, 43~65A,
54~80A, 65~100A, 85~125A, 脱扣级别(Trip class)= 10A, 3Pole

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-1993

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR
THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Jun. 27, 2005

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE
CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: Apr. 11, 2003)



President:

李怀林

Li Huailin



A10 Chaoyangmenwaidajie Beijing 100020 P.R.China <http://www.cqc.com.cn>

A 0204879