



# 中国国家强制性产品认证证书

证书编号: 2003010309037407

## 申请人名称及地址

LS产电  
汉城 中区 南大门路5街 84-11

商标: LS

## 制造商名称及地址

LS产电  
汉城 中区 南大门路5街 84-11

## 生产企业名称及地址

LS产电 清州工厂  
韩国清州市兴德区松正洞1号

## 产品名称和系列、规格、型号

热过载继电器

型号: GTH-150/3, GTK-150, Ue=AC380V, 440V, Ie=34~50A, 39~57A, 43~65A, 54~80A, 65~100A, 85~125A, 100~150A, 脱扣级别(Trip Class)=10A, 3Pole

## 产品标准和技术要求

GB14048.4-1993

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2005年6月27日

本证书的有效性依据发证机构的定期监督获得保持。

(本证书为变更证书, 证书首次颁发日期: 2003年4月10日)



主任:

李怀林



中国·北京·朝阳门外大街甲10号 100020 网址: www.cqc.com.cn

A 0204873



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2003010309037407

## NAME AND ADDRESS OF THE APPLICANT

LS Industrial Systems Co., Ltd.  
84-11, Nandaemunno5(o)-ga, Jung-gu, Seoul, Korea

TRADE MARK: LS

## NAME AND ADDRESS OF THE MANUFACTURER

LS Industrial Systems Co., Ltd.  
84-11, Nandaemunno5(o)-ga, Jung-gu, Seoul, Korea

## NAME AND ADDRESS OF THE FACTORY

LS Industrial Systems Co., Ltd. CheongJu Plant  
1. Songjeong-dong, Heungdeok-gu, Cheongju-si, Chungchengbuk-do, Korea

## NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

型号:GTH-150/3, GTK-150, Ue=AC380V, 440V, Ie=34~50A, 39~57A, 43~65A,  
54~80A, 65~100A, 85~125A, 100~150A, 脱扣级别(Trip Class)=10A, 3Pole

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-1993

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR  
THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: Jun. 27, 2005

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE  
CERTIFICATION BODY AT REGULAR INTERVALS

(ORIGINAL ISSUED DATE: Apr. 10, 2003)



President:

李怀林

Li Huailin



A10 Chaoyangmenwaidajie Beijing 100020 P.R.China <http://www.cqc.com.cn>

A 0204873